



**NOTE:**

SEWER LATERAL SHALL BE DUCTILE IRON PIPE, OR SLEEVED IF PVC. SLEEVE SHALL EXTEND 10' AWAY FROM POINT OF INTERSECTION. (EACH SIDE)

NOTE: IT IS PREFERABLE TO PLACE THE SEWER & IRRIGATION LATERALS BELOW WATER PIPES AND SEPARATE THEM BY AT LEAST 12". THIS DETAIL APPLIES WHEN SEWER OR IRRIGATION LATERAL IS CLOSER THAN 12" TO WATER PIPE.

<b>OILDALE MUTUAL WATER CO.</b>	
POTABLE/DOMESTIC WATER MAIN CROSSING 12" OR LESS ABOVE SEWER LATERAL	
DATE: 8/1/13	PLATE No. 13A