



CHRISTY/OLDCASTLE G-5 VALVE BOX & G05CT LID

CHRISTY/OLDCASTLE UTILITY BOX & RISERS AS REQUIRED BY OMWC SEE TABLE ON THIS PLATE

8" PVC RISER INTO G5 BOX

GROUND SURFACE

OMWC APPROVED METER WITH ERT & BYPASS

MUELLER R/W GV TYP.

36" MIN.

3'-6" MIN.

GRAVEL OR OMWC APPROVED MATERIAL

OMWC CUSTOMER OWNERSHIP

CONCRETE SUPPORT BLOCK (TYP.)

SECTION A-A  
N.T.S.

MUELLER R/W GATE VALVE, FLANGE x MJ

DR-18 PVC WATER MAIN

PROPERTY LINE

DUCTILE IRON PIPE OR C900 PVC, RESTRAINED

8" PVC RISER, G5 BOX W/G5CT LID

D.I. FLANGED 90° ELBOW

D.I. FLANGED SPOOL 2' MIN.

A

A

METER SIZE	METER BOX	BOX LID
3"	B48	B48M2
4"	B48	B48M2
6"	B52	B52M3
8"	B52	B52M3

SEE PLATE NO. 8

MUELLER R/W GATE VALVE (TYP.)

D.I. REDUCER AS NEEDED

MUELLER R/W GATE VALVE

REV. DATE: 1/19/16

2'-0"

PLAN  
N.T.S.

**OILDALE MUTUAL WATER COMPANY**

POTABLE/DOMESTIC 3"-8" WATER SERVICE CONNECTION

NOTE: ELEVATION CHANGE WILL BE MADE BY 45° FITTINGS ONLY.

DATE: 8/1/13

PLATE No. 6