


PLAN
N.T.S.

NOTES

1. DIMENSIONS TO BE SAME FOR ALL SIZES OR TYPES OF OPENINGS.
2. CONCRETE MAY BE DELETED ON ROAD MIX STREETS UPON APPROVAL OF INSPECTOR.
3. CONCRETE TO BE CLASS "A" (SIX SACK).
4. CONCRETE TO BE BARRICADED FOR THREE DAYS AFTER POURING.
5. CONCRETE CURE TO BE IN ACCORDANCE WITH SECTION 90-7 "CURING CONCRETE" OF THE STANDARD SPECIFICATIONS PER COUNTY/CITY MOST CURRENT EDITION.
6. USE OLDCASTLE/CHRISTY BOXES AND LIDS AS FOLLOWS:
 3/4" SERVICE B12 BOX W/B12-61G LID
 1" SERVICE B16 BOX W/B16-61G LID
 1-1/2" - 2" SERVICE B36 BOX W/B36-61G LID
 3" - 4" SERVICE B48 BOX W/B48-62G LID
7. SEND RFI TO OMWC FOR LARGER OR MULTIPLE APPLICATIONS.
8. VALVE BOX LIDS SHALL BE MARKED "WATER".



ELEVATION
N.T.S.

REV. DATE: 2/18/19

OILDALE MUTUAL WATER CO.

POTABLE/DOMESTIC
METER BOX IN PAVED AREA

DATE: 8/1/13

PLATE No. 12A