


PLAN
N.T.S.

NOTES

1. DIMENSIONS TO BE SAME FOR ALL SIZES OR TYPES OF OPENINGS.
2. CONCRETE MAY BE DELETED ON ROAD MIX STREETS UPON APPROVAL OF INSPECTOR.
3. CONCRETE TO BE CLASS "A" (SIX SACK).
4. CONCRETE TO BE BARRICADED FOR THREE DAYS AFTER POURING.
5. CONCRETE CURE TO BE IN ACCORDANCE WITH SECTION 90-7 "CURING CONCRETE" OF THE STANDARD SPECIFICATIONS PER COUNTY/CITY MOST CURRENT EDITION.
6. USE OLDCASTLE/CHRISTY BOXES AND LIDS AS FOLLOWS:
 3/4" SERVICE B12 BOX W/B12D LID
 1" SERVICE B16 BOX W/B16D LID
 1-1/2" - 2" SERVICE B36 BOX W/B36E LID
 3" - 4" SERVICE B48 BOX W/B48 M2 LID
7. SEND RFI TO OMWC FOR LARGER OR MULTIPLE APPLICATIONS.
8. VALVE BOX LIDS SHALL BE MARKED "WATER".



ELEVATION
N.T.S.

REV. DATE: 2/18/19

OILDALE MUTUAL WATER CO.

POTABLE/DOMESTIC METER
BOX IN LANDSCAPE AREA

DATE: 8/1/13

PLATE No. 12C