



NOTE:

SEWER LATERAL SHALL BE DUCTILE IRON PIPE, OR SLEEVED IF PVC. SLEEVE SHALL EXTEND 10' AWAY FROM POINT OF INTERSECTION. (EACH SIDE)

NOTE: IT IS PREFERABLE TO PLACE THE SEWER & IRRIGATION LATERALS BELOW WATER PIPES AND SEPARATE THEM BY AT LEAST 12". THIS DETAIL APPLIES WHEN SEWER OR IRRIGATION LATERAL IS CLOSER THAN 12" TO WATER PIPE.

OILDALE MUTUAL WATER CO.	
POTABLE/DOMESTIC WATER MAIN CROSSING 12" OR LESS ABOVE SEWER LATERAL	
DATE: 8/1/13	PLATE No. 13A